

Test Verification of Conformity

Verification Number: 181102331SHA-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant **CE** mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	Zhejiang Chint Electrics Co., Ltd. No 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zh Province, P.R.China
Manufacturing site Name & Address:	Zhejiang Chint Electrics Co., Ltd. No 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zh Province, P.R.China
Product Description:	Circuit-breakers with overcurrent protection
Ratings & Principle Characteristics:	See Annex pages
Models/Type References:	eBG, eB, eBC
Brand Name(s):	CHINT
Standard(s)/Directive(s):	EN 60 898-1:2003 + A1:2004 + A11:2005+A12:2008+A13:2012 Low Voltage Directive 2014/35/EU
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Test Report Number(s):	181102331SHA-001


Signature

Name: Oliver Wei
Position: Manager
Date: 30 January 2019

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 181102331SHA-V1

Ue=240/415V or 230/400V~(1P), 415V or 400V~(2P, 3P, 4P)
In= 1, 2, 3, 4, 5, 6, 10, 16, 20, 25, 32, 40, 50, 60, 63A (for B-, C-type)
In= 1, 2, 3, 4, 5, 6, 10, 16, 20, 25, 32, 40, 50, 60, 63A (for 1P&2P, D-type)
In= 6, 10, 16, 20, 25, 32, 40, 50, 60, 63A (for 3P&4P, D-type)
B-, C- and D-type, 50/60Hz
Icn= Ics= 4500A (eB)
Icn= Ics= 3000A (eBC)
Icn= Ics= 6000A (eBG, In= 1~40A, B-&C-type)
Icn= Ics= 4500A (eBG, In= 50~63A, B-&C-type; In= 1~63A, D-type)



Signature

Name: Oliver Wei

Position: Manager

Date: 30 January 2019

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.