



Declaration of Conformity

Certificate No.: ATJC22061580002400S

Reference Report No. : ATJC22061580002400S

Applicant : YUEQING CET ELECTRIC CO., LTD

Address : XINGUANG INDUSTRIAL ZONE, LIUSHI TOWN, YUEQING CITY,
ZHEJIANG PROVINCE, CHINA

Manufacturer : YUEQING CET ELECTRIC CO., LTD

Address : XINGUANG INDUSTRIAL ZONE, LIUSHI TOWN, YUEQING CITY,
ZHEJIANG PROVINCE, CHINA

Product Description : Isolating switch

Model No. : LW119G, LW219G, LW319G, LW419G, SF119G, SF219G, SF319G,
SF419G, LWSF-125, SFT263, SFT363, SF463, SFT240, SFT340,
SFT440, LWFT240, LWFT340, LWFT440, LWFT263, LWFT363,
LWFT463, LWSF-63, LWFT-63

Rating(s) : Input: 220-1000V~, 125Amax
Output: 220-1000V~, 125Amax

Trademark : 

The above products have been tested by us with listed standards and found in compliance with the Directive 2014/35/EU. It is possible to use CE marking to demonstrate the compliance with this Directive.

Test Standards	: EN IEC 60947-3:2021
----------------	-----------------------

The certificate is based on a single evaluation of tested samples of above-mentioned product. It does not imply an assessment of the whole production and does not permit the use of the test laboratory logo.



Authorized Signer :



Shenzhen An-Teng Testing Service Co., Ltd

Floor 5, No. 11, Hebei Industrial Zone, Hualian Community, Longhua Street, Longhua District, Shenzhen, China.

Tel: 86-755-27724522 Fax: 86-755-27724533 Web: www.antenglab.com