

# ATTESTATION OF CONFORMITY

Issued to: Zhejiang Chint Electric Co., Ltd.  
No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,  
325603 Zhejiang, China

For the product: Residual current operated circuit-breakers with integral overcurrent protection  
(RCBO)

Trade name: CHINT

Type/Model: NB1L

Ratings: 1P+N, Ue = 220 / 230 / 240 Vac, 50 Hz, In = 2, 4, 6, 10, 13, 16, 20, 25, 32, 40 A,  
B and C type, I<sub>dn</sub> = 30, 100, 300 mA, type A and AC, without time-delay, I<sub>cs</sub>: 6000 A  
or 7500 A, I<sub>cn</sub>: 6000A or 10000 A, I<sub>dm</sub> = 3000 A, Energy limiting class 3

Manufactured by: Zhejiang Chint Electric Co., Ltd.  
No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,  
325603 Zhejiang, China

Subject: Type Test

Remark: This Attestation replaces AoC no. 3310241.01A issued on 2016-08-25.

Requirements: EN 61009-1:2012, EN 61009-1:2012/A1:2014, EN 61009-1:2012/A2:2014,  
EN 61009-1:2012/A11:2015, EN 61009-1:2012/A12:2016, EN 61009-2-1:1994,  
EN 61009-2-1:1994/A11:1998, IEC 61009-1:2010, A2:2013, A1:2012,  
IEC 61009-2-1:1991

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in reports No W0811042.50 issued on 2009-08-13, 3302588.50 issued on 2011-08-22, 3302588.52 issued on 2011-10-17, 3306652.50 issued on 2014-10-28, 3310241.50 issued on 2016-08-09 and 3314711.50 issued on 2018-11-09.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 20 November 2018      Number: 3314712.01A

DEKRA Testing Services (Zhejiang) Co., Ltd.

Ms J Guo  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed  
The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

DEKRA Testing Services (Zhejiang) Co., Ltd.  
No. 5, Changjiang Road Great Bridge Industrial Park North Baixiang, Wenzhou, Zhejiang, 325603, P. R. China  
T +86577628680 00 F +86577629198 89 www.dekra-certification.com

