

RCC

(REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO

SWITCH TECHNIQUE KZN (PTY) LTD

IN TERMS OF SANS 10142 CLAUSE 4.
ISSUED BY

National Regulator for Compulsory Specifications

PRODUCT: TRANSFER SWITCH - MTSE (S-TEC) EDCO;

$U_e = 415V\text{-(2P, 4P)}; U_i = 500V; I_e = 63, 100, 125A; U_{imp} = 4kV; I_{cm} = 17kA; I_{cr} = 10kA, 30 ms;$
 $50Hz; \text{Category AC-32A}$

Test Laboratory:

LCIE

In accordance to(Standards):

IEC 60947-1:2007 + A1:2010

IEC 60947-6-1:2005 + A1:2013

Test report no: AGM-15DE1386TSP

RCC No: 1908076

Period of Validity

15/08/2019 to 15/08/2021



NRCS - Electrotechnical General Manager.

DATE 2019-08-16

